

## **Specification**

The Translucent Sheeting shall be Ampelite Webglas GC SL 3660 Industrial Fiberglass Sheeting as supplied by Ampelite (NZ) Limited. Webglas GC uses Ampelite's Proprietary SL Group 3 "Bromine Free" Fire Retardant Resin System as standard meeting Fire Group 3 rating. The thickness of the sheet shall be 2.2mm in the chosen commercial roofing profile.

## **Warranty**

Webglas SL is coated with a 100 micron Silmar **SIL12BE-996** gel coat layer on the outer surface of the sheet forming a barrier which is resistant to the detrimental effects of UV light, minimizing long term yellowing and maintaining mechanical properties. Webglas SL Industrial Fiberglass sheeting carries a 25 year warranty in respect of light transmission and water transmission and foot traffic.

## **Installation**

Webglas SL sheeting shall be installed in accordance with Ampelite fixing instructions and with AS/NZS 1562.3:1996, Design and installation of sheet roof and wall cladding, Part 3: Plastic, the requirements of the NZ building code and the NZ Metal Roofing Manufacturers Association Code of Practice.

FOR FULL INSTALLATION DETAILS PLEASE DOWNLOAD A COPY OF OUR INSTALLION GUIDE:

### **Please note these additional important requirements:**

Webglas SL shall be installed using the fastening length applicable to the chosen profile. The sheeting must be installed by pre-drilling 12mm oversize holes to allow for expansion and contraction. The fixing screws shall be located in the centre of the rib must not be over tightened to an extent that the sheet buckles, allowing water penetration at the seal or sheet overlap. Fixing should be made at every second crest at both ends of the sheet, and every third crest at intermediate purlin's. Webglas SL sheeting shall only be installed using Metal profiled washer along with

an EPDM washer which fits the profile correctly ensures the fixings remain watertight.

### **To ensure accuracy Ampelite recommends the following:**

- 1- Install screws into the Webglas SL sheeting in the same manner as metal.
- 2- When completed, remove fixings from the Webglas SL sheet.
- 3- Using the existing screw hole as a guide, re drill over sizing the hole.

- 4- Re install the fixing screw. (Note how the screw is centrally located in the hole.)
- 5- Do not over tighten the screw putting undue pressure on the Webglas SL sheet.

### **Purlin Protection**

Webglas SL is a trafficable fiberglass sheet and in most applications Safety mesh may not be needed. However, if safety mesh must be incorporated under the Webglas SL sheeting a purlin protection strip must be provided where the Webglas SL roof sheeting passes over safety mesh sitting on the supporting purlin, a Ampelite purlin protection strip must be placed directly under the Webglas SL sheeting. This profile strip will protect the Webglas SL from damage when fastened.

### **Side laps**

If Webglas SL is to be used as skylights, the metal roof sheets need be laid with the correct spacing's left for the skylights. Where Webglas SL is to be used as a complete roof, then the sheeting should be laid in the same fashion as metal roofing.

### **Side Stitching**

It is recommended to install additional side stitching fasteners. These fasteners will bond the Webglas SL sheeting and the adjacent sheeting together with appropriate allowances for the differential expansion rates of the materials. Ampelite recommends either Ampelite Lap Stitch or a T17 coarse treaded self-drilling screw with the same metal profiled washer and seal being use on the primary fasteners these instances.

The Lap Stitch is a compressed fastener designed to secure the side laps of fibreglass sheets (fibreglass onto fibreglass). It consists of a neoprene sleeve with an embedded nut, plus a stainless screw with matching washer. When drawn up properly, it offers equal bearing on both sides of the secured sheets and draws them together without cracking or crazing.

When fibreglass sheeting is lapped onto metal sheeting a T17 coarse treaded self-drilling screw with the same metal profiled washer and seal being use on the primary fasteners, fastened into the top of the rib, provides a firm seal in the lapping joint. The table below indicates the recommended spacing for side stitching fasteners.

<b>Profile Rib Height</b>	<b>Max Spacing of Fasteners</b>
30mm and less	450mm
30mm and more	600mm

### **End Laps**

All end laps must have a minimum of 300mm overlap. Ampelite recommend the use of either a 25mm x 5mm closed sell foam tape or a bead of sealant at the top and

bottom of the fastening point. End lapping should only be applied to roofs with a minimum pitch of 3 degrees.

### **Span Information**

Webglas SL has been designed to be trafficable roof sheeting and for this reason it is very important the sheeting is installed with the correct purlin spacings. Please contact your local Ampelite branch with the wind load in Kpa and we will provide you with the span data for your chosen profile.

### **Sealing at flashings**

The use of end stops is recommended to prevent wind driven water from running passed the flashing and into the building. Typically, a metal angle is folded to the height of the profile rib and fastened to the end of the sheet with rivets. Neutral cure sealant is then applied where the Fibreglass sheet meets the metal angle.

### **Wall Cladding**

Pan fixing is required at each girt, and use of Ampelite grey dome 22 mm weather seals ensures a weather tight seal. Over tightening or flattening the weather seal must be avoided. Fixing shall occur in every pan at both ends of the sheeting, and every other pan at intermediate grits.

### **End Closure Strip**

Foam filler strip is available to suit most profiles. This strip should be installed at the ends of the sheets to exclude dirt, birds and vermin.

### **Cutting**

Should cutting of the Webglas SL sheet onsite be necessary the use of a circular saw with a small tooth blade suitable for plastic sheeting is recommended. Care should be taken to achieve a cut with minimal damage to the sheet.

### **Storage**

The sheeting should always be stored in a dry and fire safe area. Do not store heavy materials on top of sheets as they may fracture.

### **Trafficable Sheeting**

Ampelite Webglas SL Fibreglass sheeting is a trafficable roof sheeting as long as the sheeting has been installed at the correct purlin spacing's as per Ampelite's recommendations. Sheets should be handled with care to avoid damage to the surface coating (Silmar **SIL 12BE-996**). Guarantees will not apply to sheeting that has been damaged in handling, or mechanical damage as a result of foot traffic.

## **Labelling**

Every translucent sheet shall be labelled with the manufactures license number, Manufacturer's name, sheet type, date of manufacture, batch number and weight.

## **Standards**

As a minimum the manufacturing process shall comply with AS/NZS 4256 and where this standard conflicts with this specification this specification shall take precedence.

## **Quality Assurance**

The manufacturer shall be AS NZS ISO 9001:2002 accredited and shall demonstrate that the correct manufacturing process has been followed and that the translucent sheet is within the specified tolerances.